



A CRISIL-NSIC RATED COMPANY
ISO-9001-2008 COMPANY

Member Of



AIMCAL (USA)




A.M.P.E.R.E (EUROPE)

In Association With



ELECTRO MAGNETIC innovative technologies

Kerone Research & Development Centre (KRDC),
B/47, Addl. MIDC. Anand Nagar, Ambarnath (East), Thane- 421 506, India
Tel- +91-251-2620542/43/44/45/46, Email-info@kerone.com, www.kerone.com



**Batch Microwave+Convection Heat
Treatment for Sterilization of MBV powder**

ISO 9001-2008 | ISO 9001-2015 | EMS 14001 | OHSAS 18001
In Association with SVCH-Technologii, Moscow (Russia)



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambarnath (East), Thane- 421 506, India
Tel- +91-251-2620542/43/44/45/46, Email-info@kerone.com, www.kerone.com

Customer :	M/s. Frigorifico Allana Private Ltd., Aurangabad
Process :	Batch Microwave+Convection Heat Treatment for Sterilization of MBV powder

TEST REPORT No: 47/KRDC/LAB/17 Mum 22/07/2019

Date Sample reception : 22/07/2019
ID : 47/LAB/122

SAMPLE DESCRIPTION:

Sampling : As Requested
Sample Condition : Acceptable
Quantity : 4 sealed packets
Sampling date : 23/07/2019
Product : MBV powder
Requirement : Sterilization
Start Date test : 23/07/2019
End Date test : 23/07/2019

LABORATORY EXPERIMENTAL SET UP:



Format: F/R&D/01



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambarnath (East), Thane- 421 506, India
Tel- +91-251-2620542/43/44/45/46, Email-info@kerone.com, www.kerone.com

LAB BATCH MICROWAVE+CONVECTION HEATING SYSTEM SPECIFICATIONS:

Microwave Power	2 kW(CW)
Frequency	2450 MHz \pm 50
Convective Power	3.5 kW (air flow 350 l/min at 20°C)
Microwave Exposure Zone (cavity)	1 cubic meter
Mode Stirrer	One
Thermal Monitoring System	Single Channel Fiber Optic: Range -40 to 250°C
Exhaust Power	1HP
Tray Size	450x950x50 mm

ENVIRONMENT-LABORATORY AMBIENT CONDITIONS:

Temperature (degree C)	29°C (\pm 5°C)
Humidity (%)	\leq 90% RH
Pressure (kN/m ² or kPa)	Not recorded

Note for recommendation: Environmental conditions have a direct impact on test results. Accuracy and consistency of test data are affected by the laboratory conditions



EQUIPMENTS USED:

Name of Equipment	Picture of Equipment	Specifications
Compact Thermal Imaging Camera		Model :FLIR E-30 Resolution: 160x 120IR Thermal sensitivity of 0.10°C
Moisture Analyzer		Make: Axis Balance Description: Moisture range: 1%(sample 0.02/0.05g), 0.1% (Sample 0.5/5g), 0.01%(Sample>5g)
Thermo Hygrometer		Model No: HTC-2 Temperature accuracy: $\pm 1^{\circ}\text{C}$ (1.8°F) Temperature resolution: 0.1°C (0.2°F) Humidity range: 10%~99% RH Humidity accuracy: $\pm 5\%$ RH Humidity resolution: 1% RH

SAMPLE PREPARATION AND METHOD/PROCEDURE:

The experiment has been performed on given MBV powder samples without adding any additive to speed up the drying rate for sterilization treatment. For this experimental run, sealed packet of given sample has been placed as it is in microwave heating system and treatment has been given. The observations are made for various parameters. Initial moisture content, final moisture content has been taken.




Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambarnath (East), Thane- 421 506, India
Tel- +91-251-2620542/43/44/45/46, Email-info@kerone.com, www.kerone.com

ANALYTICAL RESULTS:

Trial No.	Power (kW)	Hot Air Temp(°C)	Cycle Time (minutes)	Sample Weight(gms)	Product Temp(°C)	Remarks, if any
1.	1.5	60	3	503	43-47	No physical change
2.	2	80	3	515	51-55	No physical change
3.	2	80	5	515	78-81	No physical change

THERMAL IMAGE SHOWING TEMPERATURE PROFILE:



BEFORE AND AFTER PICTURES OF TREATED SPCIMEN SAMPLE:



Format: F/R&D/01



Kerone Research & Development Centre (KRDC)

B/47, Addl. MIDC. Anand Nagar, Ambarnath (East), Thane- 421 506, India
Tel- +91-251-2620542/43/44/45/46, Email-info@kerone.com, www.kerone.com

MOISTURE ANALYSIS REPORTS:

Drying started		Drying started	
Date : 23-07-2019		Date : 23-07-2019	
Time : 13:54:19		Time : 14:29:00	
Model: AGS200		Model: AGS200	
Serial number : 138		Serial number : 138	
Drying parameters		Drying parameters	
Product : Test		Product : Test	
Drying temperature : 105.0 °C		Drying temperature : 105.0 °C	
Drying profile : standard		Drying profile : standard	
Mode : Short mode		Mode : Short mode	
Calculation : $((m_0 - m) / m_0) \times 100\%$		Calculation : $((m_0 - m) / m_0) \times 100\%$	
Finished : 3 samples		Finished : time over	
Initial weight : 1.437 g		Initial weight : 1.230 g	
Final weight : 1.365 g		Final weight : 1.169 g	
Drying time : 00:03:00s		Drying time : 00:02:24s	
Sampling interval : 20 sec		Sampling interval : 20 sec	
Moisture : 5.0 %		Moisture : 5.0 %	
NOTE Initial		NOTE Final	
The analysis performed by:		The analysis performed by:	
Signature: <i>K Komal</i>		Signature: <i>K Komal</i>	

OBSRVATIONS:

The Drying behavior of MBV powder has been investigated under the microwave+convection heating system for sterilization treatment. The heating rate is found to be increasing with respect to increasing heating time. As per physical investigation, it has been observed that there is in no change in treated sample.

K Komal

Miss Komal Bhoite
Tested By

Format: F/R&D/01